



ICC CODE CORNER

2015 International Fire Code®

Reprinted for Campus Fire Safety e-NewZone with permission from the International Code Council (ICC)

SECTION 509

FIRE PROTECTION AND UTILITY EQUIPMENT IDENTIFICATION AND ACCESS

509.1 Identification. Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location shall be constructed of durable materials, permanently installed and readily visible.

509.1.1 Utility identification. Where required by the fire code official, gas shutoff valves, electric meters, service switches and other utility equipment shall be clearly and legibly marked to

identify the unit or space that it serves. Identification shall be made in an approved manner, readily visible and shall be maintained.

509.2 Equipment access. Approved access shall be provided and maintained for all fire protection equipment to permit immediate safe operation and maintenance of such equipment.

Storage, trash and other materials or objects shall not be placed or kept in such a manner that would prevent such equipment from being readily accessible.

NEXT ISSUE:
SECTION 510
EMERGENCY RESPONDER RADIO
COVERAGE
(page 1771)



ICC CODE CORNER

2015 International Fire Code®

Reprinted for Campus Fire Safety e-NewZone with permission from the International Code Council (ICC)



The International Code Council, a membership association dedicated to building safety and fire prevention, develops the codes used to construct residential and commercial buildings, including homes and schools. Most U.S. cities, counties and states that adopt codes choose the International Codes developed by the International Code Council.



The Center for Campus Fire Safety
978.961.0410
SupportTeam@campusfiresafety.org